

COMMERCIAL DEVELOPMENT MANAGER UPDATE – 15th February 2016

Gleann Dubhlinn hydro scheme

Renewables First have confirmed that the coanda screen was manufactured wrongly and have carried out a temporary fix. A replacement screen will be manufactured in March.

Horgabost Wind Turbine

SSE were able to tap down the voltage supply from the transformer on 31st January. Tests have shown that there is no excess voltage at the energy shed so supplies to the housing and centre are safe. Further tests will be carried out and a transformer is to be changed before the turbine will run permanently.

Pairc Niseaboist- Community Building

At the time of writing final works are being carried out on the building with handover expected on Friday 17th February. The EV charge point was installed on 14th February.

Luskentyre Mast

EE have now indicated that they wish to construct their own mast adjacent to the Vodafone one.

Carloway visit

2 people from the Carloway Community Association who are looking to purchase their old school from CnES will be visiting on 13th March to learn from WHT experiences.

Duncan MacPherson

15th February 17